

UL INTERNATIONAL (UK) LTD Wonersh House, Building C, The Guildway, Old Portsmouth Road, Guildford. GU3 1LR. United Kingdom.





designated according to Article 29 of the Regulation (EU) No 305/2011 and member of EOTA (European Organisation for Technical Assessment, www.eota.eu)

## European Technical Assessment

ETA 17/0211 of 01/03/2017

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: UL International (UK) Ltd

Trade name of the construction product

Seals WCD I-matt

Product family to which the construction product belongs

Fire Stopping and Sealing Product:

Penetration Seals

Manufacturer

FireCare Brandwerende Technieken B.V.

loge Maa

3964 Ne Wij bij Duurstede

THE NEW

A/003

Manufacturing plant(s)

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of

7 pages including 1 Annex which forms an integral part of this assessment.

ETAG 026-2, edition 2011, used as European Assessment Document (EAD).

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

## **Table of Contents**

I.	ECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT	. 3
1	Technical description of the product	. 3
2	Specification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): ETAG 026-2	. 3
3	Performance of the product and references to the methods used for its assessment	. 4
4	ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE	. 5
5	Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD	. 5
6	Issued on:	. 6
ANNI	A – Resistance to Fire Classification – Seals WCD I-matt	. 7
A.	Flexible wall constructions with wall thickness of minimum 100 mm	. 7
	1.1 Cable penetration seal with 3.8 mm thick Seals WCD I-matt in socket hov	7

