



UL INTERNATIONAL (UK) LTD  
Wonersh House, Building C,  
The Guildway,  
Old Portsmouth Road,  
Guildford. GU3 1LR.  
United Kingdom.



designated according to Article 29 of the Regulation (EU) No 305/2011 and member of EOTA (European Organisation for Technical Assessment, [www.eota.eu](http://www.eota.eu))

## European Technical Assessment

**ETA 17/0212**  
**of 01/03/2017**

**Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011:** **UL International (UK) Ltd**

**Trade name of the construction product**

Seals Brandwerende Mortel G

**Product family to which the construction product belongs**

Fire Stopping and Sealing Product:  
• Penetration Seals

**Manufacturer**

FireCare Brandwerende Technieken B.V.  
Kogewaat 1  
3961 NC Vijlshuis Duurstede  
The Netherlands

**Manufacturing plant(s)**

A/003

**This European Technical Assessment contains**

57 pages including 1 Annex which forms an integral part of this assessment.

**This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of**

ETAG 026-2, edition 2011, used as European Assessment Document (EAD).

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

## Table of Contents

<b>I.</b>	<b>SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT</b>	<b>3</b>
1	Technical description of the product	3
2	Specification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): ETAG 026-2	3
3	Performance of the product and references to the methods used for its assessment	5
4	ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE	6
5	Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD	6
6	Issued on:	7
<b>ANNEX A</b>	<b>Resistance to Fire Classification – Seals Brandwerende Mortel G</b>	<b>8</b>
A.1	Rigid wall constructions according to 1.2.1 with wall thickness of minimum 150 mm	8
A.1.1	Cable penetration seal with 50 mm deep Seals Brandwerende Mortel G backed with mineral fibre board	8
A.1.2	Pipe penetration seal with 50 mm deep Seals Brandwerende Mortel G backed with mineral fibre board	10
A.1.3	Pipe penetration seal with 50 mm deep Seals Brandwerende Mortel G backed with mineral fibre board	11
A.1.4	Cable penetration seal with 100 mm deep Seals Brandwerende Mortel G	13
A.1.5	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	14
A.1.6	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	17
A.1.7	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	18
A.1.8	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	20
A.1.9	Pipe penetration seal with 50 mm deep Seals Brandwerende Mortel G to both faces	22
A.2	Rigid floor constructions according to 1.2.1 with floor thickness of minimum 150 mm	23
A.2.1	Cable penetration seal with 50 mm deep Seals Brandwerende Mortel G backed with mineral fibre board	23
A.2.2	Pipe penetration seal with 50 mm deep Seals Brandwerende Mortel G backed with mineral fibre board	25
A.2.3	Cable penetration seal with 100 mm deep Seals Brandwerende Mortel G	28
A.2.4	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	29
A.2.5	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	31
A.2.6	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	33
A.2.7	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	36
A.2.8	Pipe penetration seal with 100 mm deep Seals Brandwerende Mortel G	38
A.2.9	Pipe penetration seal with 50 mm deep Seals Brandwerende Mortel G	40
A.2.10	Pipe penetration seal with 50 mm deep Seals Brandwerende Mortel G	42
A.2.11	Pipe penetration seal with 50 mm deep Seals Brandwerende Mortel G	43
A.2.12	Cable penetration seal with 150 mm deep Seals Brandwerende Mortel G	44
A.2.13	Cable penetration seal with 150 mm deep Seals Brandwerende Mortel G	45
A.3	Flexible wall constructions according to 1.2.1 with wall thickness of minimum 100 mm	46
A.3.1	Cable penetration seal with 25 mm deep Seals Brandwerende Mortel G to both faces backed with 50 mm mineral fibre board	46
A.3.2	Pipe penetration seal with 25 mm deep Seals Brandwerende Mortel G to both faces backed with 50 mm mineral fibre board	48
A.3.3	Pipe penetration seal with 25 mm deep Seals Brandwerende Mortel G to both faces backed with 50 mm mineral fibre board	50
A.3.4	Pipe penetration seal with 25 mm deep Seals Brandwerende Mortel G to both faces backed with 50 mm mineral fibre board	52
A.3.5	Pipe penetration seal with 25 mm deep Seals Brandwerende Mortel G to both faces backed with 50 mm mineral fibre board	53
A.3.6	Pipe penetration seal with 25 mm deep Seals Brandwerende Mortel G to both faces backed with 50 mm mineral fibre board	54
A.3.7	Pipe penetration seal with 50 mm deep Seals Brandwerende Mortel G to both faces	56