



UL INTERNATIONAL (UK) LTD  
Wonersh House, Building C,  
The Guildway,  
Old Portsmouth Road,  
Guildford. GU3 1LR.  
United Kingdom.



designated according to Article 29 of the Regulation (EU) No 305/2011 and member of EOTA (European Organisation for Technical Assessment, [www.eota.eu](http://www.eota.eu))

## European Technical Assessment

**ETA 17/0213**  
**of 01/03/2017**

**Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: UL International (UK) Ltd**

**Trade name of the construction product**

Seals Buis Wrap

**Product family to which the construction product belongs**

Fire Stopping and Sealing Product:  
• Penetration Seals

**Manufacturer**

FireCare Brandwerende Technieken B.V.  
Kogewaat 1  
3961 NC Vijlshuis Duurstede  
The Netherlands

**Manufacturing plant(s)**

A/003

**This European Technical Assessment contains**

40 pages including 1 Annex which forms an integral part of this assessment.

**This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of**

ETAG 026-2, edition 2011, used as European Assessment Document (EAD).

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

## Table of Contents

<b>I.</b>	<b>SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT</b>	<b>3</b>
1	Technical description of the product	3
2	Specification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): ETAG 026-2	3
3	Performance of the product and references to the methods used for its assessment	5
4	ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE	6
5	Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD	6
6	Issued on:	7
A.1	Rigid wall constructions with wall thickness of minimum 150 mm	8
A.1.1	Seals Buis Wrap penetration seals, in 100 mm thick Seals Brandwerende Mortel Gseals in rigid walls with insulated metal pipes	8
A.1.2	Seals Buis Wrap penetration seals, in 100 mm thick Seals Brandwerende Mortel Gseals in rigid walls with plastic pipes	11
A.2	Rigid floor constructions with a minimum thickness 150 mm	12
A.2.1	Seals Buis Wrap penetration seals, in 100 mm thick Seals Brandwerende Mortel Gseals in rigid floors, with insulated metal pipes	12
A.2.2	Seals Buis Wrap penetration seals, in 100 mm thick Seals Brandwerende Mortel Gseals in rigid floors, with insulated metal pipes	14
A.2.3	Seals Buis Wrap penetration seals, in 100 mm thick Seals Brandwerende Mortel Gseals in rigid floors, with insulated metal pipes	16
A.2.4	Seals Buis Wrap penetration seals, in 100 mm thick Seals Brandwerende Mortel Gseals in rigid floors, with plastic pipes	18
A.2.5	Seals Buis Wrap penetration seals, in 50 mm thick Seals Brandwerende Mortel Gseals, backed with 50 mm stone wool, in rigid floors, with plastic pipes	20
A.3	Flexible and rigid wall constructions with a minimum thickness 100 mm	21
A.3.1	Seals Buis Wrap penetration seal for insulated metal pipes, in seals comprising 25 mm deep Seals Brandwerende Mortel Gto both faces backed with 50 mm mineral fibre board, installed within flexible or rigid wall	21
A.3.2	Seals Buis Wrap penetration seal for composite pipes, in seals comprising 25 mm deep Seals Brandwerende Mortel Gto both faces backed with 50 mm mineral fibre board, installed within flexible or rigid wall	23
A.3.3	Seals Buis Wrap penetration seal for insulated metal & composite pipes, in seals comprising 25 mm deep Seals Brandwerende Mortel Gto both faces backed with 50 mm mineral fibre board, installed within flexible or rigid wall	24
A.3.4	Seals Buis Wrap penetration seal for insulated metal pipes, in seals comprising 50 mm deep Seals Brandwerende Mortel Gto both faces, installed within flexible or rigid wall	25
A.4	Rigid wall constructions with floor thickness of minimum 150 mm	27
A.4.1	Seals Buis Wrap penetration seal for insulated metal pipes, in 1x Seals Board Coated Board seals, in rigid walls	27
A.5	Rigid floor constructions with floor thickness of minimum 150 mm	28
A.5.1	Seals Buis Wrap penetration seal for plastic pipes, in 1x Seals Board Coated Boards, in rigid floors	28
A.5.2	Seals Buis Wrap penetration seal for insulated metal pipes, in 1x Seals Board Coated Boards, in rigid floors	29
A.5.3	Seals Buis Wrap penetration seal for insulated metal pipes in 2x Seals Board Coated Boards (separated), in rigid floors	30
A.5.4	Seals Buis Wrap penetration seal for insulated metal pipes, in 2x Seals Board Coated Board (back to back), in rigid floors	31
A.6	Flexible or rigid wall constructions with wall thickness of minimum 100 mm	33
A.6.1	Seals Buis Wrap penetration seal for insulated metal pipes, in 2x Seals Board Coated Board, in flexible or rigid walls	33
A.6.2	Seals Buis Wrap penetration seal for insulated metal pipes, in 2x Seals Board Coated Board, in flexible or rigid walls	35
A.6.3	Seals Buis Wrap penetration seal for insulated metal pipes, in 2x Seals Board Coated Board, in flexible or rigid walls	36
A.6.4	Seals Buis Wrap penetration seal for plastic pipes, in 2x Seals Board Coated Board, in flexible or rigid walls	37
A.6.5	Penetration seal in Seals Brandwerende Mortel Gseals, in flexible* and rigid walls minimum 100 mm thick	39